



PUBLIC WORKS DEPARTMENT
ENGINEERING DIVISION
156 S. BROADWAY, SUITE 150
TURLOCK, CA 95380-5461

PHONE: (209) 668-5520
FAX: (209) 668-5563
TDD: (800) 735-2929
engineering@turlock.ca.us

Date: 03/22/2023

City Project No.: 22-030

Addendum No.: 2

Plan holders:

Revisions to Specifications

The following additions, deletions or modifications shall become part of the Contract Documents:

Strikethrough text (~~text~~) indicates deletions. Bold Italicized text (**text**) indicates additions

Item No. 1:

Section 10 Construction Details

10.01 SCOPE OF WORK:

1. Removal and disposal of all interior partitions (4 total).
2. Install ***an aluminum flat trim*** cover on the West wall after existing tracks are removed.
3. Furnish and ~~install 3080 single swing entrance doors with panic off set, 10" bottom kick plate and overhead concealed closer to meet ADA compliance~~ ***install bronze anodized medium stile out swing doors, ADA 105HO concealed closer, gear hinge, AR8800 panic hardware, 10" kick panel to meet ADA compliance. Complete frame and bronze threshold*** for the North, South, and East walls.
4. Furnish and install sliding window wall system; OBE 2000 series, Class 1, bronze anodized ***frame with 10" ADA kick panel on all panels*** with 1/4" tempered glass.
5. Install window package (stated in 2 and 3) consisting of single swing entrance door and sliding wall system to be ~~mulled~~ ***mulled*** together into 1 opening in field by glazing contractor.
6. As per requirements, 1/4" clear tempered glass to be used.
7. Use configuration "~~OXXXXXO~~" "***OXX/XXX,***" ***two (2) left sliders stacking behind stationary panel, three (3) right sliders stacking behind swing door on stack off track*** for the North, South, and East walls.
8. All ADA doors are to be keyed alike.
9. Refer to Appendix A for additional technical requirements. All product information provided in these Special Provisions and Appendix A shall be as listed, or approved equal.

Item No. 2:

Notice to Contractors

Paragraph 6:

~~A mandatory~~ ***An optional*** pre-bid meeting will be held on Thursday, March 23rd, 2023 at 10 AM in the Turlock Senior Citizens Center located at 1191 Cahill St, Turlock, CA 95380. ~~General contractors must attend the meeting to be eligible for award of the contract.~~

Special Provisions: Section 1 Specifications and Plans

Special Notes:

2. ~~A mandatory~~ **An optional** pre-bid meeting will be held on Thursday, March 23rd, 2023 at 10 AM in the Turlock Senior Citizens Center located at 1191 Cahill St, Turlock, CA 95380. ~~General contractors must attend the meeting to be eligible for award of the contract~~

Section 2: Proposal Requirements and Conditions

2.01 General:

The Contractor's attention is directed to the "Notice to Contractor" for the date, time and location of the ~~mandatory~~ **optional** Pre-Bid meeting, if applicable.

If you have any questions, please call me at (209) 668-6029 or email at ccalvario@turlock.ca.us.

Sincerely,



Charlotte Calvario
Engineering Project Coordinator