

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Por favor hable con alguien que lo pueda traducir.

***Para obtener más información, llame al (209)668-5590.***

### City of Turlock Has levels of 1,2,3-TCP Above Drinking Water Standards

Our water system recently failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received in November 2020 show our system exceeds the standard, or maximum contaminant level (MCL), for 1,2,3-trichloropropane (1,2,3-TCP). The standard for 1,2,3-TCP is 0.005 ug/L (micrograms per liter) equivalent to 0.000005 mg/L (milligrams per liter). The average level of 1,2,3-TCP for the period of December 2019 – November 2020 for three out of the eighteen drinking water wells was 0.01941 ug/L, ranging from 0.0059 ug/L to 0.0431 ug/L.

#### What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.**
- This is not an immediate risk. If it had been, you would have been notified immediately. However, *some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

#### What happened? What was done?

On December 14, 2017 the State Water Resources Control Board's Division of Drinking Water established a MCL and monitoring frequencies for 1,2,3-TCP that went into effect January 2018. Due to the newly adopted MCL, the City of Turlock has three wells that have exceeded the allowable limits for the contaminant.

As a result, the City is required to increase monitoring frequencies for 1,2,3-TCP, develop a corrective action plan, and distribute a public notice to all drinking water customers every three months until the wells are no longer producing levels of 1,2,3-TCP above the MCL.

The City anticipates resolving the problem by June 30, 2021.

#### For more information, please contact:

Municipal Services

Phone: (209) 668-5590

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

#### Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by the City of Turlock in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.



## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Por favor hable con alguien que lo pueda traducir.

***Para obtener más información, llame al (209)668-5590.***

### City of Turlock Has levels of 1,2,3-TCP Above Drinking Water Standards

Our water system recently failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received in November 2020 show our system exceeds the standard, or maximum contaminant level (MCL), for 1,2,3-trichloropropane (1,2,3-TCP). The standard for 1,2,3-TCP is 0.005 ug/L (micrograms per liter) equivalent to 0.000005 mg/L (milligrams per liter). The average level of 1,2,3-TCP for the period of December 2019 – November 2020 for three out of the eighteen drinking water wells was 0.01941 ug/L, ranging from 0.0059 ug/L to 0.0431 ug/L.

#### What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.**
- This is not an immediate risk. If it had been, you would have been notified immediately. However, *some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

#### What happened? What was done?

On December 14, 2017 the State Water Resources Control Board's Division of Drinking Water established a MCL and monitoring frequencies for 1,2,3-TCP that went into effect January 2018. Due to the newly adopted MCL, the City of Turlock has three wells that have exceeded the allowable limits for the contaminant.

As a result, the City is required to increase monitoring frequencies for 1,2,3-TCP, develop a corrective action plan, and distribute a public notice to all drinking water customers every three months until the wells are no longer producing levels of 1,2,3-TCP above the MCL.

The City anticipates resolving the problem by June 30, 2021.

#### For more information, please contact:

Municipal Services

Phone: (209) 668-5590

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

#### Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by the City of Turlock in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.



## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Por favor hable con alguien que lo pueda traducir.

***Para obtener más información, llame al (209)668-5590.***

### City of Turlock Has levels of 1,2,3-TCP Above Drinking Water Standards

Our water system recently failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received in November 2020 show our system exceeds the standard, or maximum contaminant level (MCL), for 1,2,3-trichloropropane (1,2,3-TCP). The standard for 1,2,3-TCP is 0.005 ug/L (micrograms per liter) equivalent to 0.000005 mg/L (milligrams per liter). The average level of 1,2,3-TCP for the period of December 2019 – November 2020 for three out of the eighteen drinking water wells was 0.01941 ug/L, ranging from 0.0059 ug/L to 0.0431 ug/L.

#### What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.**
- This is not an immediate risk. If it had been, you would have been notified immediately. However, *some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

#### What happened? What was done?

On December 14, 2017 the State Water Resources Control Board's Division of Drinking Water established a MCL and monitoring frequencies for 1,2,3-TCP that went into effect January 2018. Due to the newly adopted MCL, the City of Turlock has three wells that have exceeded the allowable limits for the contaminant.

As a result, the City is required to increase monitoring frequencies for 1,2,3-TCP, develop a corrective action plan, and distribute a public notice to all drinking water customers every three months until the wells are no longer producing levels of 1,2,3-TCP above the MCL.

The City anticipates resolving the problem by June 30, 2021.

#### For more information, please contact:

Municipal Services

Phone: (209) 668-5590

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

#### Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by the City of Turlock in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.





**SRWA**  
STANISLAUS REGIONAL  
WATER AUTHORITY

# CONSTRUCTION NOTICE

## REGIONAL SURFACE WATER SUPPLY PROJECT (TURLOCK WATER TRANSMISSION PIPELINE)

What	A 42-in diameter welded steel water pipeline will be installed to convey drinking water from the Stanislaus Regional Water Authority water treatment plant to the City of Turlock.
When	Construction is scheduled to begin on January 21, 2021. Construction notice door hangers will be provided to properties along the pipeline route 7 days before the start of construction in affected areas.
Where	The pipeline will be installed in portions of Aldrich Road, Fox Road, Berkeley Road, Taylor Road and North Quincy Avenue to the City's future water tank located east of North Quincy Road, south of Zeering Road.
What to Expect	Construction activities involve pipeline trench excavations in and adjacent to roadways. Traffic controls will be used through construction zones and roadways will either be plated or restored at the end of each workday.
Traffic Impacts	Detours and traffic controls will be provided for road closures during construction as needed. Access will be maintained for properties fronting the construction work.
Work Hours	Monday - Friday, 7:00 a.m. – 5:00 p.m. and Saturday, 7:00 a.m. – 4:00 p.m.
Contacts	If you have questions or concerns, please visit the SRWA Website at <a href="https://stanrwa.com/">https://stanrwa.com/</a> or call the 24-hour construction information hotline at (888) 226-0986 for more information. You can also follow @StanRWA on Twitter, Facebook and Instagram for project updates.





## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Por favor hable con alguien que lo pueda traducir.

***Para obtener más información, llame al (209)668-5590.***

### City of Turlock Has levels of 1,2,3-TCP Above Drinking Water Standards

Our water system recently failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received in November 2020 show our system exceeds the standard, or maximum contaminant level (MCL), for 1,2,3-trichloropropane (1,2,3-TCP). The standard for 1,2,3-TCP is 0.005 ug/L (micrograms per liter) equivalent to 0.000005 mg/L (milligrams per liter). The average level of 1,2,3-TCP for the period of December 2019 – November 2020 for three out of the eighteen drinking water wells was 0.01941 ug/L, ranging from 0.0059 ug/L to 0.0431 ug/L.

#### What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.**
- This is not an immediate risk. If it had been, you would have been notified immediately. However, *some people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

#### What happened? What was done?

On December 14, 2017 the State Water Resources Control Board's Division of Drinking Water established a MCL and monitoring frequencies for 1,2,3-TCP that went into effect January 2018. Due to the newly adopted MCL, the City of Turlock has three wells that have exceeded the allowable limits for the contaminant.

As a result, the City is required to increase monitoring frequencies for 1,2,3-TCP, develop a corrective action plan, and distribute a public notice to all drinking water customers every three months until the wells are no longer producing levels of 1,2,3-TCP above the MCL.

The City anticipates resolving the problem by June 30, 2021.

#### For more information, please contact:

Municipal Services

Phone: (209) 668-5590

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

#### Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by the City of Turlock in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.